



# Verification of conformity

## No. ICR Polska/VC/C200903

**Name and address of applicant:** FERRO S.A.  
ul. Przemysłowa 7, 32-050 Skawina, Polska/Poland

**Name and address of manufacturer:** FERRO S.A.  
ul. Przemysłowa 7, 32-050 Skawina, Polska/Poland

**Product name:** Pompa cyrkulacyjna wody pitnej / Circulation pump for drinking water

**Product types:** (1): GPD 25-40-130, (2): GPD 25-40-180,  
(3): GPD 25-60-130, (4): GPD 25-60-180, (5): GPD 32-60-180,  
(6): GPD 25-80-180, (7): GPD 32-80-180

**Ratings:** 230 V~; 50-60 Hz; 65 W<sub>(1, 2)</sub>; 100 W<sub>(3, 4, 5)</sub>; 245 W<sub>(6, 7)</sub>; klasa I/class I; IP44

**Product trademark:** **FERRO®**

This document confirms that the product sample meets the requirements of the following standards:

- Related with Directives **2014/35/EU** (LVD), **2014/30/EU** (EMC) and **2011/65/EU** (RoHS):

|                                    |                   |                   |
|------------------------------------|-------------------|-------------------|
| EN 62233:2008                      | EN 55014-1:2017   | EN 62321-3-1:2014 |
| EN 60335-1:2012+A11:2014+A12:2017  | EN 55014-2:2015   | EN 62321-4:2014   |
| EN 60335-2-51:2003+A1:2008+A2:2012 | EN 61000-3-2:2014 | EN 62321-5:2014   |
|                                    | EN 61000-3-3:2013 | EN 62321:2009     |

The assessment process has been carried out in accordance with individual rules and conditions agreed with the applicant. Evaluation has been carried out in accordance with:

**Test reports:** BW/76/2015, BW/70/2014, 125/15

**Test conducted by:** PCBC S.A.

**Issue date:** 07.09.2020

**Expiration date:** 06.09.2025

#### Remarks

This Verification of conformity refers to the above mentioned product and its conformity in regards of above mentioned standard(s) was proven on test sample.

This Verification of conformity was issued on voluntary basis and does not imply meeting all essential requirements, assessment of the series-production or any other restricted Notified Bodies conformity assessment procedure appropriate for the product.



marking remarks:

mark is not sanctioned by the following verification of conformity mark given here as reference, can be only use by the manufacturer after applying all essential requirements from relevant directives

document status can be checked: <https://cert.icrpolska.com/>



Director: Rafał Kalinowski

